

ADDENDUM “A”

Request for Bids RFB #14-0910

Four Trailer Mounted 100kw Generators

THIS ADDENDUM HEREBY CLARIFIES, MODIFIES, or RESPONDS to QUESTIONS received regarding the Randolph County **Request for Bids #14-0910** for Four Trailer Mounted 100kw Generators issued on Wednesday, September 10, 2014. This Addendum is being issued to notify potential Vendors of changes, additions, or needed clarifications that are being made to the specifications of **RFB #14-0910**.

The following is a question that has been received by Randolph County and the County’s response:

***Question 1. Sections 4.10 Modes & Section 4.11 Power Distribution
What is the voltage being used?***

Answer: It will be the responsibility of the County to install transfer switches on facilities it deems critical for emergency power. The generator will need to be able to handle all voltages (single phase and three phase) depending on which facility it may be deployed.

Question 2. Sections 4.12 Females Receptacles & 4.13 Males Receptacles, who is the manufacturer?

Answer: The manufacturer of these receptacles is Crouse-Hinds by Eaton. Another manufacturer may be used as long as the specifications match.

Question 3. Please clarify Section 4.13. Are these supposed to be male plugs that fit into the female receptacles in Section 4.12? We have been unable to identify the part numbers and please specify the quantity.

Answer: The female cam-lock receptacles (Section 4.12) should be installed and wired on the generator with a protective weather cover so that a cable (supplied by the County) can be ran from the generator to the male counterpart (Section 4.13). Item 4.13 should be shipped loose, and will be installed by the County on the facility in which the generator may be used.

Question 4. Does the ship to location have a receiving dock?

Answer: Yes, the county has secured a loading dock to receive the shipment

Question 5. Will the product be used only on Randolph County's property or will it be used on roads?

Answer: The purpose of the generators is to supply emergency power in times of disaster for buildings or deployed in the field (Example: a mobile field hospital, command center, etc.). The generator has the potential to be deployed anywhere in the state of North Carolina.

Question 6. Does Randolph County already have similar trailers and how are they being used and plated?

Answer: Similar trailer-mounted generators have been purchased and used to supply emergency power in times of disaster for buildings or deployed in the field. The trailer must be titled and it will be the responsibility of the recipient to plate the unit.

Issued Wednesday, September 17, 2014